From:	Dann Hart
To:	"Amanda Dixon"
Cc:	kcopplestone@w3group.net
Subject:	RE: WCAA Access Parking Mod Submittal No. CW7
Date:	Sunday, May 06, 2012 11:23:00 AM
Attachments:	White Chlorinated Rubber Fast Dry MSDS 12W-D289.pdf White Chlorinated Rubber Fast Dry Product 12W-D289.pdf

---

Hello:

The waterborne paint is for painting over sealcoated parking lots only, not parking decks.

I think 12W-D289 will do. This is what we used and accepted when the deck was first striped by us (I think back in 2001). **We do not use 12W-D310, it was a mistake you received the sheets**. We want to use 12W-D289. See enclosed. We can add beads to the yellow, gravity fed only by employees. We cannot mix beads into the paint before spraying, that will ruin our equipment. I don't think we priced the arrows with beads by the way but we can do it. I hope this does it for all.

Dann Hart
Hart Pavement Striping
P.O. Box 300998
Waterford, MI 48330
Cell: 248-762-9170
248-684-4191 Fax: 248-684-4194
www.hartstriping.com
ddhart@hartstripingc.om

From: Amanda Dixon [mailto:amanda@alsasphalt.com]
Sent: Friday, May 04, 2012 8:43 AM
To: ddhart@comcast.net
Cc: jim@alsasphalt.com
Subject: FW: WCAA Access Parking Mod Submittal No. CW7

Please review and get back with me as soon as possible.

Thanks,

Amanda Dixon
Al's Asphalt Paving Co. Inc
25500 Brest Rd
Taylor, Mi 48180
T- 734-946-1880
F- 734-946-4502

From: Kellie Copplestone [mailto:kcopplestone@w3group.net]
Sent: Thursday, May 03, 2012 6:40 PM

To: ed@alsasphalt.com; 'Amanda Dixon'
Subject: FW: WCAA Access Parking Mod Submittal No. CW7

Please review the attached.

Resubmit the white pavement marking paint and data for traffic arrow beads ASAP for further review.

Thanks,
Kellie Copplestone
W3 Construction Co.

From: Greg Ehmke [mailto:gehmke@carlwalker.com]
Sent: Thursday, May 03, 2012 5:16 PM
To: Kellie Copplestone
Cc: Kelly Ferencz (kelly.ferencz@wcaa.us); Rachel Sugden
Subject: RE: WCAA Access Parking Mod Submittal No. CW7

Kellie,
Attached is the return on the pavement marking materials submittal.
Greg

From: Kellie Copplestone [mailto:kcopplestone@w3group.net]
Sent: Thursday, April 26, 2012 3:11 PM
To: Greg Ehmke
Cc: Kelly Ferencz (kelly.ferencz@wcaa.us)
Subject: WCAA Access Parking Mod Submittal No. CW7

Please review the attached submittal no. CW7.

Thanks,
Kellie Copplestone
W3 Construction Co.
(313) 999-7489 cell